

Saltford WRC has been identified through the AMP7 WINEP development process as requiring an increase to its FFT permit.

WINEP ID	Scheme Name/Name of Investigation/Site Name/License name	Driver Code(s)	Measure Type	Proposed Permit Limit Other
7WW200053	BATH (SALTFORD) STW	U_IMP5	Intermittent Discharge	Increased FFT

The improvement is required to ensure compliance with the requirements of the Urban Wastewater Treatment Regulations.

Increased FFT will ensure that storm tanks do not fill prematurely and are emptied effectively to prevent more frequent, higher strength and longer duration spills from storm tanks to receiving waters, and allow receiving waters to respond to rainfall events to provide additional dilution. EA guidance requires that in calculating the proposed FFT permit there should be no spills to storm on a “dry day”; the definition of a “dry day” being a day with less than 0.25mm of rainfall.